

Application

The RD-521-NP-G ceiling radiation damper employs butterfly style blades for point-of-origin control of radiant heat in HVAC systems. The RD-521-NP-G is installed horizontally in the ceiling membrane of combustible floor-ceiling or roof-ceiling assemblies with fire resistance ratings up to and including 1 hour. The RD-521-NP-G must have a field assembled outlet box installed on it.

Standard Construction

Frame: 22 gauge (0.85) galvanized steel.

Blades: 22 gauge (0.85) galvanized steel — butterfly. Insulated with ceramic refractory material for dampers larger than 114 in.² (735 cm²).

Transition: None (field adaptation required).

Plaster Ground: 5/8" (16) deep × 1" (25) wide Std.

Closure Device: Fusible link.

Fire Closure Temperature: 165°F (75°C).

Minimum Size: 4" × 6" (102 × 152)

Maximum Size: Square: 16" × 16" (406 × 406)
Rectangular: 24" (610) W or 20" (508) H
with a maximum area of 256 in.² (1652 cm²).

Options

- ☐ Alternate Frame Length:
 - ☐ 5 1/4" (133) ☐ 7" (178) ☐ Other _____
- ☐ Alternate 212°F (100°C) fire closure temperature.
- ☐ VC — volume control device factory mounted:
- ☐ WHI installation angle set:
 - 2 angles 1" × 1/2" × 28" long (25 × 13 × 711) × 20 ga. (1.0)
 - 2 angles 1" × 1/2" × 3" long (25 × 13 × 76) × 20 ga. (1.0)
- ☐ Boot rail installation set:
 - 2 pieces 25" (635) long.

Ratings

UL 555C Fire Resistance Rating: 1 hour for installation in floor designs L-521, L-528, L-546, L-558, L-562, L-574, L-576, L-581, L-583, L-585, M-509, M-540 and in roof/ceiling designs P-522, P-533, P-538, P-545, P-547, P-579, and P-580.

Listings


UL 555C listing: R-14980

CSFM listing: 3226-1404:100


Warnock Hersey listing #: WHI-495-PSH-0177, -0178

Meets NFPA Standards: 90A and 101

Meets Building Code Standards: IBC, NBC, NFPA, SBC and UBC



Model RD-521-NP-G
(standard)
*Damper dimensions furnished approximately net O.D.



RD-521-NP-G